



**PRODUCT NUMBER: 2091907**  
**ELECTROSOFT CLASS 0**

For electrical work with a maximum voltage of 1000 volts. To be used with leather protectors for mechanical protection.



**Overview**

**Reference Number**  
 2091907

**Product Type**  
 Gloves

**Range**  
 Electrical Protection

**Line**  
 Latex

**Brand**  
 Honeywell

**Brand formerly known as**  
 ELECTROSOFT

**Industry**

- Energy or Electricity
- Maintenance
- Telecoms

**Product Use**  
 For electrical work with a maximum voltage of 1000 volts. To be used with leather protectors for mechanical protection.

**Features & Benefits**

**Feature**  
 Beige natural latex insulating glove  
 Cut edge  
 Category RC  
 Thickness 1 mm

**Benefit**  
 COMFORT  
 Its ergonomic shape and lightly powdered interior make the glove easy to slip on and off.

RESISTANCE  
 Its natural latex base offers high dielectric characteristics.  
 Its thickness ensures good dexterity while offering protection up to 1,000 volts.

**SAFETY**

To be used with leather protectors for mechanical protection.

**Technical Description**

**Description**

CE CATEGORY : III Irreversible risks

In accordance with standards :

EN 60903 : 2003

CEI 903 : 2002

**CHARACTERISTICS :**

Beige natural latex insulating glove

Category RC

**Product Technology**

Dipped Gloves

**Glove/liner color**

Beige

**Coating Type**

Latex

**Length**

36 cm

**Thickness**

1 mm

**Harmlessness**

In conformity with the European standards

**Dexterity**

Class 0

**Sizes**

8 to 11

**Packaging Label**

**Tagging**

CE HONEYWELL

2091907 XX

EN 60903-2003

CEI 903-2002

**Certifications**

**EC Category PPE**

3

**Quality Assurance**

ISO 9001 / 2000

**EC Certificate Number**

7005

**EC Attestation**

EC Attestation

**EC Attestation Number**

7005

**Certifications**

- Other 0333

**Additional Information**

**User Information Sheet**

On the polybag

**Maintenance**

**Life Cycle**

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months

**Storage Information**

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

**Care Instructions**

Inspection : Before each use, carry out a visual inspection and check the glove inflation.

Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity